

MISCELLANEOUS FURNISHINGS & FIXTURES - SECTION 12100

1.0 - GENERAL

- 1.1 Scope
The work of this section consists of furnishing and installing complete, all miscellaneous furnishings and fixture items as indicated.
- 1.2 Submittals
Shop drawings shall be submitted.
- 1.3 Warranty
Provide Manufacturer's Standard Warranty where manufacturer warrants that the Goods delivered hereunder shall be of the kind described within this agreement and free from defects in material and workmanship under conditions of normal use for a period of six (6) years. Halotron, CO2 and Water/Water based extinguisher will be warrantied for a period of five (5) years.

2.0 - PRODUCTS

- 2.1 Fire Extinguisher Cabinets (FEC)
Recessed or semi-recess U.L. approved baked enamel 18 gauge steel cabinet, 24" h. x 10-1/2" w. x 6" d. with 2-1/2" trim. Cabinet door to be baked enamel or epoxy coated with stencil lettering "Fire Extinguisher" equal to J. L. Industries-Panorama #1017 Identity Q horizontal, white w/red letters - type break glass w/cly. lock; Larsen's Mfg. Co.; Amerex Corporation; or approved equal.
- Provide comparable fire rated fire extinguisher cabinets in fire rated walls as per rating indicated.
- 2.2 Fire Extinguisher (FE)
- A. Cabinet Mounted - U.L. approved, 10 pound, tri-class dry chemical for Class A, B, & C fires. Equal to J. L. Industries - Cosmic 10E with hose; Larsen's Mfg. Co.; Amerex Corporation. Provide one with each cabinet.
- B. Wall Mounted - 10 pound, Tri-Class Dry Chemical for Class A, B, C fires, U.L. approved, Model 10 ABCS-1. Manufacturers: J.L. Industries, Larsens, Amerex Corporation.

3.0 - EXECUTION

- 3.1 Installation
Installation of all items shall be in full conformity with manufacturer's specifications, recommendations and approved details.
- 3.2 Fire Extinguishers shall be cabinet mounted in areas as indicated. Height shall be 4'-8" from floor to top of cabinet and 4'-4" from floor to top of extinguisher handles.
- 3.3 Fire Extinguishers shall be wall mounted in areas as indicated or required so that distance of travel between units does not exceed 75 feet. Each separate area shall have a minimum of one unit. Mounting height shall be 4'-6" from floor to top of handle.

END OF SECTION

